

自願性產品驗證電子證書

Certificate of the Voluntary Product Certification



證書號碼： V546056760014號99

Certificate No.

茲據 台芝電氣股份有限公司 申請自願性產品驗證，
經審查結果符合規定，准予並使用產品驗證標誌及識別號碼：
其登載事項如下：

The application made by 台芝電氣股份有限公司 for Voluntary Product Certification has been reviewed and found to be in compliance with related regulations. Therefore, registration is granted with the Certification Mark and the Identification No. V54676 Details of the registration are as follows:



申請人： 台芝電氣股份有限公司
Applicant

地址： 臺中市南屯區工業23路7號
Address

生產廠場： 台芝電氣股份有限公司
Factory

廠址： 台中市南屯區工業23號7號
Factory address

產品種類名稱： 大容量無熔線斷路器(限檢驗交流電壓600V以下，額定電流超過800A或短路容量超過220V/50kA、380V/30kA、440V/25kA及600V/20kA)
Type/name of product

中文名稱： 無熔線斷路器
Chinese name

英文名稱： MOLDED-CASE CIRCUIT BREAKER
English name

型式： NF400-HM 3P Ui690V 60Hz 400AF In=225/250/315/350/400A, Ics=42kA at 220V, 25kA at 380V, 21kA at 440V, Icu=85kA at 220V, 50kA at 380V, 42kA at 440V
Type

系列產品： 空白
Series of type

驗證標準： CNS14816-2 (93年版)
Standards

標準檢驗局發證

This certificate shall be issued by the BSMI

本證書所載內容若有不符之處，以標準檢驗局系統登錄資料為主，查詢證書資料網址：

<https://civil.bsmi.gov.tw>

核可日期： 中華民國 106 年 12 月 21 日
Registration date 2017 (year) 12 (month) 21 (day)

本證書有效期限至 112 年 12 月 20 日
Expiration Date 2023 (year) 12 (month) 20 (day)

發證日期： 中華民國 109 年 11 月 26 日
Date of issue 2020 (year) 11 (month) 26 (day)



註：次年度自願性產品驗證年費繳納期限為當年11月30日，逾期未繳納者，經限期繳納屆期未繳納，即依自願性產品驗證實施辦法第21條第8款規定廢止產品驗證，並自次年度1月1日起生效。

列印序號:5544363746160210121